

CCH 2014 Energy Consumption and Greenhouse Gas Emissions Data

Building Name	Operation Type	Address	Total Area (sq.ft.)	Electricity (kWh)	Natural Gas (m ³)	District Heating (GJ)	GHG Emissions (kg)
JMP	Hospital Purposes	840 McConnell	2,582	56,049	3,715	223	22,478
JMP	Admin & other facilities	840 McConnell	70,000	1,519,521	100,719	6,040	609,383
Main	Admin & other facilities	510 2nd Street	53,706	1,165,820	77,274	4,634	467,536
Main	Hospital Purposes	510 2nd Street	110,761	2,404,337	159,368	9,557	964,227
The Steam Plant	Admin & other facilities	510 2nd Street	3,975	86,287	5,719	0	14,266
The Annex	Admin & other facilities	840 McConnell	12,000	260,489	17,266	0	43,066
The Steam Plant	Admin & other facilities	840 McConnell	6,000	130,245	8,633	0	21,533
The Tower	Admin & other facilities	840 McConnell	79,987	1,736,313	115,089	6,902	696,325
The Tower	Hospital Purposes	840 McConnell	95,677	2,076,902	137,664	8,256	832,914
West Wing Addition	Hospital Purposes	840 McConnell	95,000	2,062,207	136,690	8,197	827,020