

Figure 3: CCH 2013 ENERGY CONSUMPTION and Green House Gas Emissions Data

Building Name	Operation Type	Address	Total Floor Area (SQFT)	Electricity KWh	Natural Gas Cubic Metre	District Heating Giga - Joule	GHG Emissions Kg
The Tower	Hospital purposes	840 McConnell	95,677.00	2661515.98	169441.44	10967.22	1,172,995.14
The Tower	Admin and other facilities	840 McConnell	79,987.00	2225055.95	141654.87	8251.69	926,258.94
JMP	Hospital purposes	840 McConnell	70,000.00	1947240.38	123968.15	8023.93	858,196.62
JMP	Admin and other facilities	840 McConnell	2,582.00	71825.35	4572.65	295.96	31,655.18
The Annex	Admin and other facilities	840 McConnell	12,000.00	333812.63	21251.68	0	65,552.76
The Steam Plant	Admin and other facilities	840 McConnell	6,000.00	166906.31	10625.84	0	32,776.38
Main	Hospital purposes	510 Second Street	110,761.00	3081118.46	196154.81	7617.76	1,056,777.66
Main	Admin and other facilities	510 Second Street	53,706.00	1493978.46	95111.91	3693.71	512,412.37
The Steam Plant	Admin and Other facilities	510 Second Street	3,975.00	110575.43	7039.62	0	21,714.35